



**EXHIBIT "C1"**  
**ARVIN-EDISON WATER STORAGE DISTRICT**  
**WATER SUPPLY WATER QUALITY SUMMARY**

	Date	Flow <sup>1</sup> cfs	Import Source	Calcium		Magnesium		Sodium		Bicarbonate		Chloride		Nitrate		TDS	pH	EC	Hardness	SAR	Gypsum	Boron	Turbidity	
				mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l									
				umhos/cm	mg/l	lbs/AF	mg/l	NTU																
Intertie Pipeline	08/11/22	0	FKC(53%)/KD WELLS(11%)/WELLS(36%)	27.0	1.35	6.6	0.54	42.0	1.81	110	1.80	34.0	0.96	11.00	0.18	220	8.38	396	94	1.9	0.19	0.26	3.4	
	07/08/22	0	FKC(20%)/KD WELLS(13%)/WELLS(67%)	34.0	1.70	8.5	0.70	43.0	1.85	140	2.30	36.0	1.01	12.00	0.19	240	8.23	442	120	1.7	ND	0.24	2.3	
	06/07/22	0	FKC(34%)/KD WELLS & KD CENTRAL(8%)/WELLS(58%)	29.0	1.45	8.1	0.66	45.0	1.94	130	2.13	38.0	1.07	11.00	0.18	230	8.4	426	110	1.9	0.73	0.24	4.3	
	05/09/22	0	KD WELLS & KD CENTRAL(12%)/WELLS(88%)	30.0	1.50	8.7	0.71	42.0	1.81	130	2.13	37.0	1.04	10.00	0.16	230	8.5	440	110	1.8	0.75	0.19	5.4	
	04/07/22	0	KD WELLS & KD CENTRAL(12%)/WELLS(88%)	33.0	1.65	9.5	0.78	36.0	1.55	140	2.30	35.0	0.98	9.50	0.15	220	8.2	402	120	1.4	ND	0.12	2.7	
	03/09/22	0	WELLS(100%)	15.0	0.75	3.0	0.25	15.0	0.65	65	1.07	10.0	0.28	4.10	0.07	90	8.2	187	51	0.9	0.24	0.07	4.4	
	02/08/22	-40	FKC(100%)	6.7	0.34	0.8	0.06	4.5	0.19	26	0.43	4.4	0.12	0.50	0.01	29	8.1	76	20	0.0	0.00	0.10	7.0	
	01/10/22	-40	FKC(100%)	9.8	0.49	0.9	0.08	5.7	0.25	41	0.67	3.5	0.10	0.54	0.01	44	7.9	87	28	0.5	0.45	0.05	4.5	
	12/13/21	N/A	DOWN FOR WINTER MAINTENANCE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	11/09/21	0	FKC(100%)	22.0	1.10	4.6	0.38	31.0	1.34	93	1.52	18.0	0.51	4.90	0.08	150	8.4	299	73	1.6	0.72	0.20	4.0	
	10/07/21	0	CVC(17%)/WELLS(83%)	38.0	1.90	12.0	0.98	48.0	2.07	150	2.46	49.0	1.38	12.00	0.19	270	8.3	477	140	1.7	ND	0.17	4.5	
	09/09/21	0	CVC(23%)/WELLS(77%)	37.0	1.85	12.0	0.98	44.0	1.90	160	2.62	49.0	1.38	13.00	0.21	260	8.2	496	140	1.6	ND	0.14	5.3	
	08/09/21	0	CVC(7%)/KD WELLS(5%)/WELLS(88%)	31.0	1.55	10.0	0.82	43.0	1.85	130	2.13	44.0	1.24	11.00	0.18	240	8.5	451	120	1.7	ND	0.15	2.4	
	07/08/21	0	CVC(7%)/KD WELLS(6%)/WELLS(87%)	32.0	1.60	9.9	0.81	43.0	1.85	150	2.46	40.0	1.12	11.00	0.18	240	8.3	453	120	1.7	0.04	0.17	1.8	
		<b>Average</b>			<b>25.8</b>	<b>1.3</b>	<b>7.2</b>	<b>0.6</b>	<b>32.5</b>	<b>1.4</b>	<b>110.5</b>	<b>1.8</b>	<b>29.8</b>	<b>0.8</b>	<b>8.0</b>	<b>0.1</b>	<b>182.1</b>	<b>8.3</b>	<b>344.9</b>	<b>93.8</b>	<b>1.3</b>	<b>0.4</b>	<b>0.1</b>	<b>4.2</b>

Water Supply Water Quality Note: <sup>1</sup> Positive flow rate is reverse flow into the District. Where the reported value is ND, the method detection limit is entered.

Water Supply Water Quality Note: <sup>2</sup> Reverse flow into the District South Canal (Sycamore check gate was closed).

Water Supply Water Quality Note: <sup>3</sup> Constituent ran past sample hold time.

ND:	NONE DETECTED.	pH:	A MEASURE OF ACIDITY. A pH < 7 IS ACIDIC, pH = 7 IS NEUTRAL, pH > 7 IS BASIC. NORMAL RANGE IS 6.5 - 8.4. A pH > 8 MAY NEED TO BE BUFFERED FOR PESTICIDE APPLICATION. AFFECTS NUTRIENT AVAILABILITY.
NA:	NOT AVAILABLE OR NOT TESTED.		
mg/l:	MILLIGRAMS PER LITER; SAME AS PARTS PER MILLION (ppm).		
me/l:	MILLEQUIVALENTS PER LITER; SAME AS EQUIVALENTS PER MILLION (epm).	EC:	ELECTRICAL CONDUCTIVITY. A MEASURE OF WATER SALINITY; SOIL - IN MILLIMHOS PER CENTIMETER (mmho/cm); WATER - MORE OFTEN, IN MICROMHOS PER CENTIMETER (umhos/cm). EC < 700 (umhos/cm) HAS NO RESTRICTIONS FOR AGRICULTURAL USE. EC < 200 (umhos/cm) CAN REDUCE INFILTRATION RATE.
INTAKE:	SAMPLE TAKEN AT COTTONWOOD RD. SOUTH OF PANAMA LANE.		
NORTH:	SAMPLE TAKEN DOWNSTREAM OF SYCAMORE CHECK GATE.		
SOUTH:	SAMPLE TAKEN DOWNSTREAM OF TEJON CHECK GATE.		
INTERTIE:	TERMINUS OF SOUTH CANAL (S93 FOREBAY).		
SODIUM:	FOR SURFACE IRRIGATION: SAR < 3 IS GOOD. FOR SPRINKLER IRRIGATION: SODIUM < 3 me/l IS GOOD.	HARDNESS:	HARD WATER, INDICATING CALCIUM AND MAGNESIUM, IS BENEFICIAL FOR AGRICULTURE.
NITRATE:	NITRATE IN WATER SLIGHTLY REDUCES FERTILIZER REQUIREMENT.		
BICARBONATE:	BICARBONATE < 1.5 me/l IS SATISFACTORY FOR OVERHEAD SPRINKLERS.		
CHLORIDE:	FOR SURFACE IRRIGATION CHLORIDE < 4 me/l IS GOOD.	SAR:	SODIUM ADSORPTION RATIO. A RATIO OF SODIUM TO CALCIUM AND MAGNESIUM. EVALUATE WITH EC. SAR = 0 - 3 AND EC > 400 ACCEPTABLE SAR = 3 - 6 AND EC > 900 ACCEPTABLE
TDS:	TDS < 450 IS ACCEPTABLE FOR UNRESTRICTED USE.		
GYPSUM:	AMOUNT OF CALCIUM SULFATE IN POUNDS PER ACRE-FOOT OF WATER APPLIED. INCREASES WATER PERMEABILITY AND HELPS CORRECT EXCESS SODIUM. INCREASES CLAY FLOCCULATION FOR INCREASING PERMEABILITY.	BORON:	BORON < 0.50 mg/l IS SATISFACTORY FOR ALL CROPS. EXCESSIVE BORON IS PHYTOTOXIC (BURNS) TO PLANTS.