

EXHIBIT "C1"
ARVIN-EDISON WATER STORAGE DISTRICT
WATER SUPPLY WATER QUALITY SUMMARY

| | Date | Flow ¹ cfs | Import Source | Calcium | | Magnesium | | Sodium | | Bicarbonate | | Chloride | | Nitrate | | TDS mg/l | pH | EC umhos/cm | Hardness mg/l | SAR | Gypsum lbs/AF | Boron mg/l | Turbidity NTU |
|--------------------------|----------|--------------------------|--|---------|-------------|------------|------------|------------|-------------|-------------|--------------|------------|-------------|------------|-------------|-------------|--------------|----------------|------------------|--------------|------------------|---------------|------------------|
| | | | | mg/l | me/l | mg/l | me/l | mg/l | me/l | mg/l | me/l | mg/l | me/l | mg/l | me/l | | | | | | | | |
| Intertie Pipeline | 12/13/21 | N/A | DOWN FOR WINTER MAINTENANCE | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| | 11/09/21 | 0 | FKC(100%) | 22.0 | 1.10 | 4.6 | 0.38 | 31.0 | 1.34 | 93 | 1.52 | 18.0 | 0.51 | 4.90 | 0.08 | 150 | 8.4 | 299 | 73 | 1.6 | 0.72 | 0.20 | 4.0 |
| | 10/07/21 | 0 | CVC(17%)/WELLS(83%) | 38.0 | 1.90 | 12.0 | 0.98 | 48.0 | 2.07 | 150 | 2.46 | 49.0 | 1.38 | 12.00 | 0.19 | 270 | 8.3 | 477 | 140 | 1.7 | ND | 0.17 | 4.5 |
| | 09/09/21 | 0 | CVC(23%)/WELLS(77%) | 37.0 | 1.85 | 12.0 | 0.98 | 44.0 | 1.90 | 160 | 2.62 | 49.0 | 1.38 | 13.00 | 0.21 | 260 | 8.2 | 496 | 140 | 1.6 | ND | 0.14 | 5.3 |
| | 08/09/21 | 0 | CVC(7%)/KD WELLS(5%)/WELLS(88%) | 31.0 | 1.55 | 10.0 | 0.82 | 43.0 | 1.85 | 130 | 2.13 | 44.0 | 1.24 | 11.00 | 0.18 | 240 | 8.5 | 451 | 120 | 1.7 | ND | 0.15 | 2.4 |
| | 07/08/21 | 0 | CVC(7%)/KD WELLS(6%)/WELLS(87%) | 32.0 | 1.60 | 9.9 | 0.81 | 43.0 | 1.85 | 150 | 2.46 | 40.0 | 1.12 | 11.00 | 0.18 | 240 | 8.3 | 453 | 120 | 1.7 | 0.04 | 0.17 | 1.8 |
| | 06/04/21 | 0 | FKC(21%)/CVC(5%)/KD WELLS(4%)/WELLS(70%) | 28.0 | 1.40 | 8.6 | 0.70 | 42.0 | 1.81 | 130 | 2.13 | 35.0 | 0.98 | 9.70 | 0.16 | 220 | 8.3 | 411 | 110 | 1.8 | 0.58 | 0.19 | 7.0 |
| | 05/07/21 | 0 | KD WELLS & KD MAIN(12%)/WELLS(88%) | 36.0 | 1.80 | 11.0 | 0.90 | 40.0 | 1.72 | 150 | 2.46 | 38.0 | 1.07 | 11.00 | 0.18 | 240 | 8.1 | 439 | 130 | 1.5 | ND | 0.13 | 3.4 |
| | 04/07/21 | 0 | KD WELLS & KD MAIN(9%)/WELLS(91%) | 36.0 | 1.80 | 12.0 | 0.98 | 41.0 | 1.77 | 150 | 2.46 | 39.0 | 1.10 | 10.00 | 0.16 | 240 | 8.3 | 431 | 140 | 1.5 | ND | 0.15 | 4.1 |
| | 03/12/21 | 0 | WELLS(100%) | 32.0 | 1.60 | 9.1 | 0.75 | 42.0 | 1.81 | 120 | 1.97 | 35.0 | 0.98 | 11.00 | 0.18 | 220 | 8.5 | 406 | 120 | 1.7 | ND | 0.16 | 3.6 |
| | 02/11/21 | 0 | CVC(18%)/WELLS(82%) | 33.0 | 1.65 | 8.9 | 0.73 | 50.0 | 2.16 | 120 | 1.97 | 48.0 | 1.35 | 10.00 | 0.16 | 240 | 8.3 | 448 | 120 | 2.0 | ND | 0.23 | 3.9 |
| | 01/11/21 | 0 | WELLS(100%) | 40.0 | 2.00 | 12.0 | 0.98 | 48.0 | 2.07 | 130 | 2.13 | 70.0 | 1.97 | 23.00 | 0.37 | 300 | 8.2 | 547 | 150 | 1.7 | ND | 0.15 | 9.0 |
| | 12/10/20 | 0 | WELLS(100%) | 30.0 | 1.50 | 8.5 | 0.70 | 61.0 | 2.63 | 110 | 1.80 | 58.0 | 1.63 | 4.30 | 0.07 | 260 | 8.4 | 513 | 110 | 2.6 | ND | 0.39 | 9.4 |
| | 11/05/20 | 0 | WELLS(100%) | 30.0 | 1.50 | 8.6 | 0.70 | 41.0 | 1.77 | 120 | 1.97 | 27.0 | 0.76 | 8.70 | 0.14 | 200 | 8.5 | 362 | 110 | 1.7 | ND | 0.15 | 1.8 |
| | | Average | | | 32.7 | 1.6 | 9.8 | 0.8 | 44.2 | 1.9 | 131.8 | 2.2 | 42.3 | 1.2 | 10.7 | 0.2 | 236.9 | 8.3 | 441.0 | 121.8 | 1.8 | 0.4 | 0.2 |

Water Supply Water Quality Note: ¹ Positive flow rate is reverse flow into the District. Where the reported value is ND, the method detection limit is entered.
Water Supply Water Quality Note: ² Reverse flow into the District South Canal (Sycamore check gate was closed).
Water Supply Water Quality Note: ³ Constituent ran past sample hold time.

| | |
|--|--|
| <p>ND: NONE DETECTED.</p> <p>NA: NOT AVAILABLE OR NOT TESTED.</p> <p>mg/l: MILLIGRAMS PER LITER; SAME AS PARTS PER MILLION (ppm).</p> <p>me/l: MILLEQUIVALENTS PER LITER; SAME AS EQUIVALENTS PER MILLION (epm).</p> <p>INTAKE: SAMPLE TAKEN AT COTTONWOOD RD. SOUTH OF PANAMA LANE.</p> <p>NORTH: SAMPLE TAKEN DOWNSTREAM OF SYCAMORE CHECK GATE.</p> <p>SOUTH: SAMPLE TAKEN DOWNSTREAM OF TEJON CHECK GATE.</p> <p>INTERTIE: TERMINUS OF SOUTH CANAL (S93 FOREBAY).</p> <p>SODIUM: FOR SURFACE IRRIGATION: SAR < 3 IS GOOD. FOR SPRINKLER IRRIGATION: SODIUM < 3 me/l IS GOOD.</p> <p>NITRATE: NITRATE IN WATER SLIGHTLY REDUCES FERTILIZER REQUIREMENT.</p> <p>BICARBONATE: BICARBONATE < 1.5 me/l IS SATISFACTORY FOR OVERHEAD SPRINKLERS.</p> <p>CHLORIDE: FOR SURFACE IRRIGATION CHLORIDE < 4 me/l IS GOOD.</p> <p>TDS: TDS < 450 IS ACCEPTABLE FOR UNRESTRICTED USE.</p> <p>GYPSUM: AMOUNT OF CALCIUM SULFATE IN POUNDS PER ACRE-FOOT OF WATER APPLIED. INCREASES WATER PERMEABILITY AND HELPS CORRECT EXCESS SODIUM. INCREASES CLAY FLOCCULATION FOR INCREASING PERMEABILITY.</p> | <p>pH: A MEASURE OF ACIDITY. A pH < 7 IS ACIDIC, pH = 7 IS NEUTRAL, pH > 7 IS BASIC. NORMAL RANGE IS 6.5 - 8.4. A pH > 8 MAY NEED TO BE BUFFERED FOR PESTICIDE APPLICATION. AFFECTS NUTRIENT AVAILABILITY.</p> <p>EC: ELECTRICAL CONDUCTIVITY. A MEASURE OF WATER SALINITY; SOIL - IN MILLIMHOS PER CENTIMETER (mmho/cm); WATER - MORE OFTEN, IN MICROMHOS PER CENTIMETER (umhos/cm). EC < 700 (umhos/cm) HAS NO RESTRICTIONS FOR AGRICULTURAL USE. EC < 200 (umhos/cm) CAN REDUCE INFILTRATION RATE.</p> <p>HARDNESS: HARD WATER, INDICATING CALCIUM AND MAGNESIUM, IS BENEFICIAL FOR AGRICULTURE.</p> <p>SAR: SODIUM ADSORPTION RATIO. A RATIO OF SODIUM TO CALCIUM AND MAGNESIUM. EVALUATE WITH EC. SAR = 0 - 3 AND EC > 400 ACCEPTABLE SAR = 3 - 6 AND EC > 900 ACCEPTABLE</p> <p>BORON: BORON < 0.50 mg/l IS SATISFACTORY FOR ALL CROPS. EXCESSIVE BORON IS PHYTOTOXIC (BURNS) TO PLANTS.</p> |
|--|--|